



Legionella Specialties

Your Water Care Specialists

(801) 918-8027

Flushing Protocol Checklist

- **Confirm your current Water Management Plan is active and includes flushing. Make sure that your flushing protocols match (at a minimum) what is described in your Water Management Plan.**
- **Identify and categorize the following distal outlets:**

High Use:

Low Use: (Increase Frequency)

Problem Area: (Increase Frequency and Duration)

Positive legionella sites: (Flush Daily Until Retesting Shows Negative)

- **Determine the following numbers for each general location i.e. floor, wing, building segment.**

ORP (Oxidation Reduction Potential): *Areas averaging <550, Increase frequency*

ATP: *Areas Averaging >5 ATP, Increase Frequency and Duration*

Free Chlorine: *Areas Averaging <.50ppm Increase Frequency*

Total Chlorine: *Areas Averaging <.50ppm Increase Frequency*

Based on the indicators above, set your flushing frequency and duration. Keep in mind that each segment may require a different flushing protocol.